

SUMMARY SNAG LIST FOR OCC BUILDING

Detailed Snag List is separately provided by the Contractor's letter P5-EN-173-03 dated 11 December 2003.

Room No./ Area	Snag/ Room Name where any Snag exists
Common	Name Plate of Room should be installed on the each door. Internal Corner between Wall and Floor should be finished. Bottom of Wall should be painted deferent color (Place, Color and Height instructed by Engineer Later). Ceiling Board Level should be fixed. Clearance between Ceiling Support and Board should be fixed. Strength of Door closer should be adjusted. Furniture should be installed and tested. Supply Water System should be tested. Wast Water System should be cleaning out. Air Conditioning System should be completed and tested. Ventilation System should be completed. Telephone System (Telephonesets) should be installed and tested. Pull Box for Interior Lighting should be covered. Lightning Protection System should be completed.
101	Power Transformer No.1 Room
102	Power Transformer No.2 Room
103	110kV GIS Room
104	24kV GIS Room
105	DC/UPS Room
106	Auxiliary Transformer No.1 Room
107	Auxiliary Transformer No.2 Room
108	LV Distribution Board room
109	Diesel Generator No.1 Room
110	Diesel Generator No.2 Room
111	Fuel Tank No.1 Room
112	Fuel Tank No.2 Room
113	AC Panel Room
114	Battery Room
115	Air Conditioning Room
116	Water Filter Reservoir Room
117	Electrical & Mechanical Workshop
118	Storage
119	Police Room
120	Driver & Storage
121	WC
122	Entrance
123	Stair Hall
124	Corridor West Area
125	Corridor East Area
126	Corridor South Area
127	Stair A F1~F2
128	Stair B F1~F2
129	Platform

SUMMARY SNAG LIST FOR OCC BUILDING

Detailed Snag List is separately provided by the Contractor's letter P5-EN-173-03 dated 11 December 2003.

Room No./ Area	Snag/ Room Name where any Snag exists
201	Electrical Control Room
202	Ventilation Control Room
203	Supervisor A Room
204	Supervisor B Room
205	Director Room
206	Vice Director Room
207	Administrator & Accountant Room
208	Conference Room
209	Storage
210	Lunch Room
211	Kitchen
212	Kitchen Storage
213	WC Men
214	WC Women
215	Deck
216	Stair Hall
217	Corridor West Area
218	Corridor East Area
219	Stair A F2~R
301	Stair Hall
302	Rooftop
W1	West side Wall 1
W2	West side Wall 2
W3	West side Wall 3
W4	West side Wall 4
W5	West side Wall 5
N1	North side Wall 1
N2	North side Wall 2
N3	North side Wall 3
E1	East side Wall 1
S1	South side Wall 1
S2	South side Wall 2
S3	South side Wall 3
ON	Outdoor North Area (Hai Van Pass)
OS	Outdoor South Area (Sea)
OE	Outdoor East Area (Back)
OW	Outdoor West Area (Front)